# RI SE

# CERTIFICATE

# Fire suppression system for engine compartment

Issued to

## **Reacton Fire Suppression Ltd**

14 Baynes Place, Waterhouse Business Park, Chelmsford, Essex, CM1 2QX, United Kingdom

## Product and product name

Reacton CTX Indirect Powder

#### Classification

Test scenario rating	Level of openness	Class A fire	
A+	4	Α	

## Technical data/Performance

See appendix to this certificate.

#### Certificate

The product described in this certificate fulfils the requirements in RISE Certification rules regarding Fire suppression systems in engine compartments of buses, coaches and other heavy vehicles, SPCR 183 issue 2020-04-06. The certification is based on the manufacturer's technical file and type tests performed in accordance with standards specified in the appendix to this certificate.

#### Marking

Marking shall show SPCR 183, RISE logo, manufacturer's logo, the number of this certificate, the name of the product, its serial number, the name of the manufacturer and RISE p-symbol. See last page in this certificate for details.

#### Validity

This certificate is valid until not longer than 2025-01-17.

#### Miscellaneous

The manufacturer's in-house inspection is under surveillance by RISE in accordance with section 4 and 5 of SPCR 183. Other terms and conditions are set out in section 6 of SPCR 183.

Martin Tillander

## Certificate C001016 | issue 2 | 2020-09-07

RISE Research Institutes of Sweden AB | Certification

Box 857, SE-50115 Borås, Sweden

📞 +46 10 516 50 00 | certifiering@ri.se | www.ri.se

2P06236

ERTIFIED

# CERTIFICATE



## **Product information**

# Technical data of the tested suppression system Reacton CTX Indirect Powder

Table 1 shows technical data of the suppression system tested for 4 m<sup>3</sup> engine compartment volumes. The system may be scaled to fit the size of a specific engine compartment according to the scaling rules in SP Method 4912.

Suppression agent type	Dry powder
Suppression agent name	Furex ABC 770
Suppression agent mass/volume	9 kg
Suppression agent container volume	121
Suppression agent container/ art number	RE-CTXCE-120-090-ABC
Suppression agent container pressure	25 bar (at +20 °C)
Propellant gas	Nitrogen
Suppression agent delivery hose	3/8" hose
Suppression agent delivery pipes	Double braided synthetic rubber. Outer diameter 19,7 mm.
Type of nozzles	5 x RE7145 1 x RE7154
Number of nozzles	6
Distance to the most remote nozzle	6 m
Total length of agent delivery system	18 m
Number of connections	6 x Straight couplings 3 x T-couplings 3 x 90° elbow
Minimum operation temperature	-40 °C
Thermal cycling resistance	ISO 16750-3:2007
Mechanical stress resistance (vibration and shock)	ISO 16750-3:2007 (Test VII)
Corrosion resistance	ISO 21207, test method B (3 cycles)

## Table 1, technical data of the tested fire suppression system

Certificate C001016 | issue 2 | 2020-09-07 RISE Research Institutes of Sweden AB | Certification

## CERTIFICATE



## Product performance

## Performance rating according to SP Method 4912

Rating	Description	Ventilation (m³/s)	Result
A +	Low fire load	3	Pass
	High fire load	3	Pass
	Hidden fire	3	Pass
Α	Hidden fire	1.5	Pass
В	Hidden fire	0	Pass
С	Low fire load	3	Pass
	High fire load	3	Pass
D	Low fire load	0	Pass
E	High fire load	0	Pass
	High fire load	1,5	Pass
	Low fire load	1.5	Pass
	Re-ignition >45s	0	Pass (63 s)

## Table 2, Fire scenario

### Table 3, level of openness:

Level	Criteria	
1	Fire tests passed with open mockup	
2	Fire tests passed without mockup floor and ceiling	
3	Fire tests passed without mockup floor	
4	Fire tests passed with all sides closed on mockup	

## Table 4, class A fire:

Description	Ventilation (m³/s)	Remarks
Class A fire	0.5	Extinguished within 60 s after activation of the suppression system.
		No re-ignition.
Pass		

Certificate C001016 | issue 2 | 2020-09-07

### $\label{eq:RISE} Research \, Institutes \, of \, Sweden \, AB \, | \, Certification$

## CERTIFICATE



## Conditions

Electrical equipment included in the system shall have a classification of at least IP65, and tested in accordance with IEC 60529:1989/A1:2009/COR3:2009.

A risk assessment in accordance with SPCR 183 section 3.2 shall be made prior to equipment being placed into service. The risk assessment shall be made by personnel having documented experience for the task.

It is the responsibility of the suppression system manufacturer to assure compliance of its suppression system components with legal requirements and vehicle manufacturer requirements.

The marking of the product shall be legible and durable and be designed as below, size 40x60 mm. It shall be applied in conjunction to the engine compartment.

Marking plate:	
RL <b>Ž</b>	manufacturer name/logo
SPCR 183	
Certificate number:	
Product name:	
Classification:	

Certificate C001016 | issue 2 | 2020-09-07 RISE Research Institutes of Sweden AB | Certification